

Qualification of Installers

Personnel qualified in accordance with CGA M-1, Standard For medical Gas Supply Systems at Health Care Facilities, or ASSE/IAMPO/ASSE 6015 Professional Qualification Standard for Bulk Medical Gas /Cryogenic Fluid Central Supply system Installers shall be permitted to install source gas manifold systems and oxygen concentrator supply units.

Statement of Problem and Substantiation for Public Input

Personnel who are qualified in accordance with CGA M-1 or ASSE 6015 have the education, training, and experience to install source gas manifold systems as well as oxygen concentrator supply units and should be permitted to install these manifolds and gas concentrator units and the piping up to but not including the source valve. Not permitting qualified personnel to install these systems would be a restraint of trade.

Submitter Information Verification

Submitter Full Name: Robert Sutter

Organization: B&R Compliance Associates

Street Address:

City: State: Zip:

Submittal Date: Wed May 01 10:44:49 EDT 2024

Committee: HEA-AAC

Copyright Assignment =

I, Robert Sutter, hereby irrevocably grant and assign to the National Fire Protection Association (NFPA) all and full rights in copyright in this Public Input (including both the Proposed Change and the Statement of Problem and Substantiation). I understand and intend that I acquire no rights, including rights as a joint author, in any publication of the NFPA in which this Public Input in this or another similar or derivative form is used. I hereby warrant that I am the author of this Public Input and that I have full power and authority to enter into this copyright assignment.

By checking this box I affirm that I am Robert Sutter, and I agree to be legally bound by the above Copyright Assignment and the terms and conditions contained therein. I understand and intend that, by checking this box, I am creating an electronic signature that will, upon my submission of this form, have the same legal force and effect as a handwritten signature